



|            |             |                 |                              |
|------------|-------------|-----------------|------------------------------|
| Number     | 17GR0053/00 | Contract number | E 8090                       |
| Issue date | 21-04-2018  | Scope           | (EU) 2016/426 (9 March 2016) |
| Due date   | 21-04-2028  | Module          | B (Type testing)             |
| PIN        | 0063CP3646  | Report number   | 141200646                    |

## EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the condensing boilers, type(s):

**GEPARD CONDENS 12 MKO -A (H-SK),  
GEPARD CONDENS 18/25 MKV -A (H-SK),  
GEPARD CONDENS 25 MKO -A (H-SK)**

manufactured by **Protherm Production s.r.o.  
Skalica, Slovak Republik**

meet(s) the essential requirements as described in the  
**Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.**

A description of the specific type(s) like model names, appliance types and categories is given in the appendix to this certificate.

CERTIFICATE

Luc Leroy, Kiwa



|            |             |               |                              |
|------------|-------------|---------------|------------------------------|
| Number     | 17GR0053/00 | Page          | 1 of 1                       |
| Issue date | 21-04-2018  | Scope         | (EU) 2016/426 (9 March 2016) |
| Due date   | 21-04-2028  | Module        | B (Type testing)             |
| PIN        | 0063CP3646  | Report number | 141200646                    |

## APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer: Protherm Production s.r.o.

Types:

| Model name                         | Appliance types   | Heat Input      |                  |
|------------------------------------|---|-----------------|------------------|
|                                    |   | CH<br>(kW - Hi) | DHW<br>(kW - Hi) |
| GEPARD CONDENS 18/25 MKV -A (H-SK) | B <sub>53P</sub> , C <sub>13</sub> , C <sub>33</sub> , C <sub>43</sub> , C <sub>53</sub> , C <sub>83</sub> ,<br>C <sub>93</sub> | 5,1 – 18,4      | 5,1 – 25,7       |
| GEPARD CONDENS 12 MKO -A (H-SK)    | B <sub>53P</sub> , C <sub>13</sub> , C <sub>33</sub> , C <sub>43</sub> , C <sub>53</sub> , C <sub>83</sub> ,<br>C <sub>93</sub> | 4,1 – 12,2      | 4,1 – 15,3       |
| GEPARD CONDENS 25 MKO -A (H-SK)    | B <sub>53P</sub> , C <sub>13</sub> , C <sub>33</sub> , C <sub>43</sub> , C <sub>53</sub> , C <sub>83</sub> ,<br>C <sub>93</sub> | 6,1 – 25,5      | 6,1 – 30,6       |

| Model name                         | Appliance categories |               | Countries     |
|------------------------------------|----------------------|---------------|---------------|
| GEPARD CONDENS 18/25 MKV -A (H-SK) | I <sub>2H</sub>      | G20 - 20 mbar | Slovakia (SK) |
| GEPARD CONDENS 12 MKO -A (H-SK)    | I <sub>2H</sub>      | G20 - 20 mbar | Slovakia (SK) |
| GEPARD CONDENS 25 MKO -A (H-SK)    | I <sub>2H</sub>      | G20 - 20 mbar | Slovakia (SK) |

Standards:

EN 15502-1:2012 + A1 : 2015, EN 15502-2-1: 2012